



# Air Vent System

The following are recommendations. Please check with your city for requirements

- Mechanical ventilation system exhausts fumes to the exterior (0.6 CFM/FT<sup>2</sup>)
- Mechanical ventilation system brings air into the salon (0.12 CFM/FT<sup>2</sup> + 20 CFM/occupant)
- Makeup air and exhaust air ducts are separate; there is no mixing recirculating, or partial makeup air
- Source capture at manicure tables and foot baths (capable of exhausting a minimum of 50 CFM per station)

## Felicity FreeForm CARESST MASSAGE

